

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Scott Walker, Governor
Paul F. Jadin, Secretary

May 17, 2011

VIEGA LLC DAVID OVERBY 4240 N COTTONWOOD LN PLYMOUTH MN 55441 VIEGA LLC DAVID OVERBY 301 N. MAIN 9<sup>TH</sup> FLOOR WICHITA KS 67202

Re: Description: PIPES AND FITTINGS, STAINLESS STEEL

Manufacturer: VIEGA LLC

Product Name: Viega ProPress Stainless & ProPress Eco Pipe

Model Number(s): Stainless Steel Pro Press pipe and fittings 1/2" through 4"

304 Stainless pipe Eco pipe and fittings 1/2" through 4"

Product File No: 20080565

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm Comm 81.40 (8) & table 84.30-8 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. Comm 84.40 (8),
  Wis. Adm. Code that requires mechanical compression type joints for water supply which use flexible
  elastomeric seals to be suitable for potable water. The intent of the code is met since this product provides an
  acceptable elastomeric seal.
- This product shall be installed in accordance to manufacture's specifications.
- Maximum Allowable Load for this product will be Table 82.40-4 found in the Wisconsin Administrative Code.

This approval supersedes the approval issued on November 14, 2008 under product file number 20080565.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080565.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08056501.DOC